



CRSI Standard for Epoxy-Coated Steel Reinforcing Bar Fabrication Facilities

1. INTRODUCTION

- 1.1. This standard describes standard practice for fabrication quality processes for epoxy-coated steel reinforcing bars. This standard specifies procedures used to monitor fabrication processes and assess quality during the handling, storage, fabrication (including bending and shearing), identification, and repair of epoxy-coated steel reinforcing bars.
- 1.2. This standard also describes minimum requirements for inspection, acceptance, documentation, and corrective actions as part of a fabrication facility quality control program, including requirements to develop and maintain a Fabrication Quality Manual (FQM).

2. REFERENCED DOCUMENTS

- 2.1. CRSI
 - 2.1.1. Manual of Standard Practice
- 2.2. ASTM International
 - 2.2.1. ASTM D3963 Standard Specification for Fabrication and Jobsite Handling of Epoxy-Coated Steel Reinforcing Bars
 - 2.2.2. A775 Standard Specification for Epoxy-Coated Steel Reinforcing Bars
 - 2.2.3. A1124 Standard Specification for Textured Epoxy-Coated Steel Reinforcing Bars

3. DEFINITIONS

- 3.1. FQM – Fabrication Quality Manual
 - 3.1.1. A manual describing the Plant commitment to and methods for obtaining quality.
- 3.2. PQS – Plant Quality Statement
 - 3.2.1. A statement from a Company Senior Executive that outlines the plant's commitment to Quality.
- 3.3. QM - Quality Manager.
 - 3.3.1. A manager responsible for all issues relating to quality of fabrication within a plant.
- 3.4. FQI – Fabrication Quality Inspector
 - 3.4.1. Personnel responsible for fabrication quality activities and documentation.
- 3.5. CRSI CA – Concrete Reinforcing Steel Institute Certification Administrator
- 3.6. IA – Inspection Agency
- 3.7. Production shift – Consecutive run time, not to exceed 12 hours.



4. FABRICATION FACILITY QUALITY PROGRAM REQUIREMENTS

All plants shall develop and maintain a Fabrication Quality Manual (FQM). The FQM shall:

- 4.1. Be signed by an authorized representative of the manufacturing organization.
- 4.2. Document facility name, street address and telephone number and the name of the contact person at the facility.
- 4.3. Describe the fabrication processes at the plant.
- 4.4. Describe requirements for annual review and updating. Changes to the FQM shall be highlighted or underlined and tracked by revision date.
 - 4.4.1. This review shall evaluate existing documentation for accuracy and conformance with current practice and applicable standards. Based on this review, changes to the FQM shall be made.
- 4.5. Include an organization chart, and a description of the duties and responsibilities assigned to key personnel in the quality program.
- 4.6. Identify the measuring and testing equipment used to determine that the product and materials meet minimum specifications.
- 4.7. Identify the frequency and methods of measuring and testing equipment calibration and requirements for record-keeping.
- 4.8. Include a PQS from a Company Senior Executive that outlines the plant's commitment to Quality and compliance with applicable ASTM standards and purchaser's specifications.
- 4.9. Describe access, including location, for all personnel involved in fabrication to:
 - 4.9.1. The FQM
 - 4.9.2. Applicable CRSI Standards
 - 4.9.3. Applicable ASTM Standards
 - 4.9.4. Applicable purchaser's recommendations or applicable standards
- 4.10. Describe methods for assurance and documentation of the presence of QM or FQI during production.
- 4.11. Describe the authority of QM and FQI.
 - 4.11.1. Include frequency of training and methods used to train the FQI and to document this training including:
 - 4.11.1.1. Training topics and materials provided to the FQI.
 - 4.11.1.2. Requirements for QM (or designated representative) led meetings to review and evaluate the quality techniques of all FQI once every six months in the plant using the manufacturer's equipment and to assess compliance with the FQM.
 - 4.11.1.3. Attendance forms signed by the FQI.
 - 4.11.1.4. Minutes of QM/QI review and evaluation meetings.



- 4.11.2. Include frequency of training and methods used to train the plant personnel and to document this training including:
 - 4.11.2.1. Training topics and materials provided to plant personnel.
 - 4.11.2.2. Attendance forms signed by the plant personnel.
- 4.12. Define requirements for documentation, observation, and testing as part of a quality program as required in Sections 5 through 12 including:
 - 4.12.1. Documentation of FQI inspections.
 - 4.12.2. Minimum acceptable levels to ensure products comply with the purchaser's specifications.
 - 4.12.3. Corrective action procedures to be taken when minimum acceptable levels are not achieved.

5. HANDLING AND STORAGE OF EPOXY-COATED REINFORCING BARS

- 5.1. Coated bars shall be handled and stored in a manner that minimizes damage to the coating.
- 5.2. Handling systems and storage racks shall have padded contact areas.
- 5.3. Bundling bands shall be padded or shall be made of a material that will prevent damage to the coating.
- 5.4. To minimize bar-to-bar abrasion from sags in the bundles, bundles shall be lifted with a strongback, spreader bar, multiple supports, or platform bridge.
- 5.5. The FQI shall examine the handling and storage systems for epoxy-coated bars once per week.
 - 5.5.1. The FQI shall document the time and results of the examination.

6. BENDING AND SHEAR

- 6.1. Fabrication Process and Equipment
 - 6.1.1. Drive rolls and backup barrels on bending equipment shall meet the requirements of ASTM D3963.
 - 6.1.2. Contact points on shear lines shall be of suitable material and condition to minimize coating damage.
 - 6.1.3. Epoxy-coated bars shall not be dragged or dropped on non-protected abrasive material (like concrete or unprotected steel) during fabrication.
 - 6.1.4. Coating on fabricated bars shall be inspected for visible cracks or damage and corrective action shall be taken if visible cracks or damage are observed.



6.1.5. The FQI shall examine the fabrication process and equipment to ensure compliance once per production day.

6.1.5.1. The FQI shall document time and results of the examination.

6.2. Dimensional Inspection of Fabricated Bars

6.2.1. Sheared lengths and dimensions of epoxy-coated bars shall meet specified dimensions within tolerances set forth by CRSI's *Manual of Standard Practice* or as specified by the purchaser.

7. BAR IDENTIFICATION AND REJECTED MATERIAL

7.1. The Plant shall maintain a bar marking and identification system that permits traceability of the bars to quality records and processes throughout the Plant.

7.2. Bars that are deemed nonconforming shall be clearly identified and marked according to the applicable standard and separated from acceptable material.

7.3. The FQI shall check inventory and bar identification tags for compliance with bar identification requirements and that rejected bars are identified and separated at least once per production shift.

7.3.1. The FQI shall document the time and results of the examination.

8. REPAIR MATERIALS

8.1. All patching material shall meet the requirements of the applicable standard.

8.1.1. Documentation that the patch material in use complies with the applicable standard shall be obtained from the material supplier.

8.1.2. The FQI shall document compliance with this requirement prior to use for each shipment of patching material.

9. REPAIR OF DAMAGED COATING

9.1. Repair Processes

9.1.1. Damaged coating shall be repaired in accordance with the patching material manufacturer's written recommendations.

9.1.1.1. The FQI shall maintain a file containing the manufacturers' written recommendations.

9.1.2. The patching material shall be used prior to its expiration date.

9.1.3. The maximum amount of repaired damaged coating shall not exceed the amount permitted by the applicable standard.

9.1.4. Repaired areas shall have a minimum coating thickness as required by the applicable standard.

9.1.5. The FQI shall examine the repair processes to ensure compliance at least once per production



week.

9.1.5.1. The FQI shall document time and results of the examination.

9.2. Inspection and Repair of Damage

9.2.1. All epoxy-coated bars shall be inspected for damaged coating before shipment to the jobsite.

9.2.2. All damaged epoxy coating (to the point of shipment to the job-site) shall be repaired with patching material.

9.2.3. The FQI shall examine the epoxy-coated bars prior to shipment to the jobsite to ensure all damage is repaired at least once per production shift.

9.2.3.1. The FQI shall document the time and results of the examination.

10. OUTDOOR STORAGE

10.1. Epoxy-coated bars shall be stored in a manner that protects them from exposure to moisture and direct sunlight if stored outside for more than 30 days.

10.1.1. The date of outdoor storage shall be documented.

10.2. The FQI shall examine any epoxy-coated bars stored outdoors at least once per week to assess length of outdoor storage and determine that the protective system is in place as required.

10.2.1. The FQI shall document the time and results of the examination.

11. EXTERNAL AUDITS

11.1. All documentation relating to external audits shall be retained in the Plant's files.

11.1.1. Action taken related to conformance shall be documented, and changes shall be made to the FQM, if required.

12. CUSTOMER COMPLAINTS

12.1. The QM or designated person addresses customer complaints and determines root cause.

12.2. Changes in procedures and/or training resulting from complaints shall be documented in the FQM.

An American National Standard: ANSI / CRSI – CG2.1 2026

**ANNEX I CRITICAL SECTIONS**

The following sections are judged to be critical sections relative to CRSI's Procedures for the Development and Maintenance of Manufacturing Certification Programs.

Designated Critical Sections for ANSI/CRSI – CG2.1-2026 CRSI Standard for Epoxy-Coated Steel Reinforcing Bar Fabrication Facilities Section	Requirement
Section 4.0	All plants shall develop and maintain a Fabrication Quality Manual (FQM).
Section 5.3	Bundling bands shall be padded or shall be made of a material that will prevent damage to the coating.
Section 6.1.2	Contact points on shear lines shall be of suitable material and condition to minimize coating damage.
Section 8.1	All patching materials shall meet the requirements of the applicable standard. 8.1.1. Documentation that the patch material in use complies with the applicable standard shall be obtained from the material supplier. 8.1.2. The FQI shall document compliance with this requirement prior to use for each shipment of patching material.

An American National Standard: ANSI / CRSI – CG2.1 2026



DISCLAIMER

Concrete Reinforcing Steel Institute ("CRSI") standards, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this Standard. Consensus does not necessarily mean that there is a unanimous agreement among every person participating in the development of this Standard.

The information in this Standard was considered technically sound by the consensus of persons engaged in its development and approval at the time it was developed. While CRSI administers the process and establishes rules to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards publications.

CRSI disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this Standard. CRSI disclaims and makes no guaranty or warranty, expressed or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this Standard will fulfill any of your particular purposes or needs.

CRSI does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this Standard. In publishing and making this Standard available, CRSI is not undertaking to render professional or other services for or on behalf of any person or entity, nor is CRSI undertaking to perform any duty owed by any person or entity to someone else. Anyone using this Standard should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstance. Information and other standards on the topic covered by this Standard may be available from other sources, which the user may wish to consult for additional views or information not covered by this Standard.

CRSI has no power, nor does it undertake to police or enforce compliance with the contents of this Standard. CRSI does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this Standard shall not be attributable to CRSI and is solely the responsibility of the certifier or maker of the statement.

CRSI takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this Standard. Users of this Standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This Standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and, if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this Standard or for additional standards and should be addressed to CRSI Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the CRSI Committee on Standards, at the address shown below.

This Standard is copyrighted by CRSI, 933 North Plum Grove Road, Schaumburg, IL 60173, United States. Individual reprints (single or multiple copies) of this Standard may be obtained by contacting CRSI at the above address or at 847-517-1200 (phone), 847-517-1206 (fax), info@crsi.org (e-mail), or through the CRSI website (www.crsi.org).